



# Myrius™

infrared sensor - 300 W

## ■ Technical data

Cat.Nos 6730 32 - 6731 32


Automatic switch




35° 0° 100 - 240 V AC 50 Hz	1 x 2,5 mm <sup>2</sup> 2 x 2,5 mm <sup>2</sup>			+ 	+ (*)
240 V AC	Max.	400 W	400 W	400 W	400 W
	Min.	40 W	40 W	40 W	40 W
100 V AC	Max.	200 W	200 W	200 W	200 W
	Min.	40 W	40 W	40 W	40 W

(\*) Use only transformers which are intended for use with an electronic switch.


### Mounting with a switch



### Mounting with offset push button




### Mounting with a several combined switch




# Myrius™ infrared sensor - 300 W




## Settings



## Operation



## Precautions of use



### Safety Instructions

GB IE

This product should be installed in line with installation rules, preferably by a qualified electrician. Incorrect installation and use can lead to risk of electric shock or fire.

Before carrying out the installation, read the instructions and take account of the product's specific mounting location.

Do not open up, dismantle, alter or modify the device except where specifically required to do so by the instructions. All Legrand products must be opened and repaired exclusively by personnel trained and approved by LEGRAND. Any unauthorised opening or repair completely cancels all liabilities and the rights to replacement and guarantees.

Use only Legrand brand accessories.